



State of Utah

JON M. HUNTSMAN, JR.  
*Governor*

GARY R. HERBERT  
*Lieutenant Governor*

## Department of Administrative Services

D'ARCY DIXON PIGNANELLI  
*Executive Director*

### Division of Facilities Construction and Management

F. KEITH STEPAN  
*Director*

## ADDENDUM #2

Date: 30 September 2005

To: Contractors

From: Bob Anderson, Project Manager

Reference: Governor's Mansion  
Salt Lake City, Utah  
Elevator Upgrades  
DFCM Project No. 05064310

Subject: **Addendum No. 2**

Pages Addendum 3 Pages

---

**Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.**

### 2.1 GENERAL

- 2.1.1 To schedule site visit, call Mike Butler at 801 209-9385.
- 2.1.2 Invitation to Bid, Page 3. Revise to read, "Bids will be received until the hour of 3:00 PM on Tuesday, October 4, 2005...."
- 2.1.3 Project Schedule, Page 4. Use revised schedule included with this Addendum.

## **2.2 DIVISION ONE**

- 2.2.1 Section 01010, Page 1, Item 1.01. Add the following,  
“F. Provide work identified in Section 01900.”
- 2.2.2 Section 01010, Page 1, Item 1.01. Add the following,  
“G. Provide interim and warranty maintenance identified in Section 01800.”
- 2.2.3 Section 01010, Page 2, Item 1.03. Add the following,  
“F. Perform work between the hours of 9:00 AM and 3:00 PM.”
- 2.2.4 Section 01600, Page 2, Item 1.05. Omit “A”, “B”, “C”. Add “A. Colors will be manufacturer’s standard.”
- 2.2.5 Section 01800, Page 1, Item 1.01 C. Revise to read, “Include cost of maintenance in modernization cost quotation.”
- 2.2.6 Section 01800, Page 1, Item 1.01 D. Omit.
- 2.2.7 Section 01900, TABLE OF CONTENTS and Page 1, Item 1.01. Change to read,  
“1.01 RELATED WORK PROVIDED BY ELEVATOR CONTRACTOR”.
- 2.2.8 Section 01900, Page 1, Item 1.01 D.1. Modify to read,  
“D. Elevator Lobbies and Car  
1. Cutting....of new fixtures.”

## **2.3 SECTION 14220**

- 2.3.1 Page 1, Item 1.01. Add, “I. Related Work in Section 01900.”
- 2.3.2 Page 1, Item 101. Add “J. Interim and Warranty Maintenance in Section 01800.
- 2.3.3 Page 1, Item 1.02. Change to read,  
“1.02 RELATED WORK  
A. If , during the course of the modernization project, items of required work are identified, the Elevator Contractor shall notify Owner and submit cost estimate/proposal to complete the work.”
- 2.3.3 Page 2, Item 1.08 A. Change to read, “...., Article 1.02 A.”

## 2.4 SECTION 14236

2.4.1 Page 1, Item 1.01 A. Add the following:

Capacity:	500 Lbs.
Number of Landings/Openings:	Four
Speed:	40 Fpm
Manufacturer:	Sedgwick

*End of Addendum*